



450 Walnut Meadows Drive
Oakley, CA 94561
Phone: (925) 625-2279
Fax: (925) 625-0169

IRONHOUSE SANITARY DISTRICT LATERAL CONDITIONS OF PERMIT

- 1. Laterals:**

Direct connection into a sewer main is not allowed.

 - a. If installing a 4-inch lateral, use approved pipe materials with a minimum slope of ¼ inch per foot. This is the usual choice for a single-family home.**
 - b. If installing a 6-inch lateral, the connection must be into a manhole using ABS pipe with a minimum slope of 1%.**

- 2. Cleanouts:**
 - a. First cleanout has to be within 18 inches of the foundation. It is recommended this cleanout be installed with an approved overflow prevention device.**
 - b. After 100 feet, another cleanout. After 135 degrees in accumulative fittings, another cleanout is required.**

- 3. Bends in lateral:**
 - a. Within the first 5 feet of a cleanout, use 45 degree elbows with 1 foot separation.**
 - b. Turns require 22 ½ degree elbows with 1 foot separation.**

- 4. Stubout connection:**

To connect to a supplied stubout, use rubber couplings with transition (green) glue or transition bands.

- 5. Septic system:**

Contact Contra Costa County Environmental Health Department for the procedure to shut down the septic system. (925)-608-5500